

**Airflow Data as of November 4, 2021**

Room	Total Air Changes/Hour	Fresh Air %	Recommended Occupancy (calibrated to fresh air %)	Results Reported	Notes
<b>LARTS</b>					
Classroom 101	7.64	75%	40	9/8/2021	
Classroom 102	7.45	75%	38	9/8/2021	
Classroom 103		75%	38		Under review
Classroom 104	10.48	50%	102	9/8/2021	
Classroom 105	8.01	50%	26	9/8/2021	
Classroom 106	8.98	50%	27	9/8/2021	
Classroom 107	7.27	75%	37	9/8/2021	
Classroom 108	7.27	75%	37	9/8/2021	
Classroom 109	7.83	75%	41	9/8/2021	
Classroom 110	7.45	75%	38	9/8/2021	
Classroom 111	8.01	75%	42	9/8/2021	
Classroom 112	7.64	75%	40	9/8/2021	
Classroom 113		75%		9/8/2021	Under review
Classroom 114	8.97	75%	48	9/27/2021	
Classroom 117	6.96	75%	211	9/27/2021	
Classroom 118	4.64	75%		9/27/2021	Under review
Classroom 119	6.21	75%	38	9/8/2021	
Classroom 120	7.14	75%	45	9/8/2021	
Classroom 121	4.50	100%	37	9/8/2021	
Classroom 202	13.38	75%	113	9/27/2021	
Classroom 203	18.50	75%	153	9/27/2021	
Classroom 203A	7.94	75%	7	9/27/2021	
Classroom 203B	8.40	75%	8	9/27/2021	
Classroom 203C	8.05	75%	7	9/27/2021	
Classroom 203D	7.70	75%	7	9/27/2021	
Classroom 203E	7.91	75%	25	9/27/2021	
Classroom 208	4.82	75%	45	9/8/2021	
Classroom 209	5.21	75%	49	9/8/2021	
Classroom 210	4.85	100%	64	9/8/2021	
Classroom 213	4.50	50%	24	9/8/2021	
Classroom 214	6.57	75%	76	9/27/2021	
Classroom 215	4.00	100%	53	9/8/2021	
Classroom 216	6.69	75%	70	9/27/2021	
Classroom 217	5.45	100%	55	9/8/2021	
Classroom 218	7.47	75%	80	9/27/2021	
<b>Auditorium</b>					
Room 006					Under review
Room 007	8.10	50%	71	9/8/2021	
<b>Charlton School of Business</b>					
Room 115	8.77	50%	77	10/14/2021	
Room 149		50%		10/14/2021	Under review
Room 240	12.45	50%	94	10/14/2021	
Room 247	9.91	50%	98	10/14/2021	
Room 248	9.89	50%	78	10/14/2021	
Room 340		50%		10/14/2021	Under review
Room 341	7.16	50%	37	10/14/2021	

CVPA					
Room 053	4.98	50%	30	9/8/2021	
Room 054	5.10	50%	23	9/8/2021	
Room 101	7.63	50%	29	9/8/2021	
Room 103	8.47	50%	35	9/8/2021	
Room 105	7.47	75%	48	9/8/2021	
Room 107	9.71	50%	44	9/8/2021	
Room 229	10.67	50%	48	9/8/2021	
Room 252	8.44	50%	50	9/8/2021	
Room 254	13.20	25%	26	9/8/2021	
Room 256	9.27	25%	22	9/8/2021	
Room 258	8.30	25%	25	9/8/2021	
Room 259	9.83	25%	19	9/8/2021	
Room 263	12.08	25%	25	9/8/2021	
Room 302	12.58	25%	37	9/8/2021	
Room 304	13.45	25%	37	9/8/2021	
Room 306	5.43	50%	53	9/8/2021	
Room 309	11.52	25%	52	9/8/2021	
Room 310	12.15	25%	38	9/8/2021	
Room 351	5.77	50%	30	9/8/2021	
Room 352	5.84	50%	37	9/8/2021	
Room 353	5.44	50%	32	9/8/2021	
Room 354	5.92	50%	31	9/8/2021	
Room 355	6.25	50%	33	9/8/2021	
Room 356	7.72	50%	38	9/8/2021	
Room 357	6.38	50%	38	9/8/2021	
Room 358	6.79	50%	38	9/8/2021	
Room 360	7.79	25%	18	9/8/2021	
Dion Science Building					
Room 101	5.93	75%	65	9/8/2021	
Room 103	6.75	75%	18	9/27/2021	
Room 105	6.47	75%	73	9/8/2021	
Room 106	4.81	75%	44	10/14/2021	
Room 107	3.62	75%	9	9/27/2021	
Room 108	10.80	50%	17	9/8/2021	
Room 109	5.16	75%	39	9/8/2021	
Room 110	5.66	75%	62	9/8/2021	
Room 112	8.58	75%	21	9/8/2021	
Room 114	4.82	75%	50	9/8/2021	
Room 115	4.12	75%		9/27/2021	Under review
Room 116	6.24	75%	126	9/27/2021	
Room 204	8.66	75%	133	9/27/2021	
Room 205	8.20	75%	28	10/14/2021	
Room 205A	8.40	75%		10/14/2021	Under review
Room 205B	5.94	75%	9	10/14/2021	
Room 205C	5.74	75%	8	10/14/2021	
Room 205D	8.20	75%	13	10/14/2021	
Room 205E	17.28	75%	18	10/14/2021	
Room 207C	6.43	75%	5	10/14/2021	
Room 207D	5.53	75%	11	10/14/2021	
Room 207E	5.19	75%	10	10/14/2021	
Room 207F	6.25	75%	14	10/14/2021	

Room 207H		75%		10/14/2021	Under review
Room 210	7.70	75%	102	9/27/2021	
Room 212	6.92	75%	43	9/27/2021	
Room 214	5.36	75%	69	9/27/2021	
Room 303	9.63	75%	64	10/14/2021	
Room 305	11.77	75%	114	10/14/2021	
Room 311	10.88	75%	92	10/14/2021	
Room 315	6.41	75%	82	10/14/2021	
<b>Law School</b>					
Room 116	5.13	75%	40	11/4/2021	
Room 117	4.37	75%	33	11/4/2021	
Room 123	4.01	75%	77	11/4/2021	
Room 207	9.17	75%	39	11/4/2021	
Room 231	4.46	75%	80	11/4/2021	
Room 232	8.00	75%	157	11/4/2021	
Room 233	4.11	75%	40	11/4/2021	
Room 234	7.00	75%	106	11/4/2021	
<b>Library</b>					
Room 128	13.55	50%	80	9/8/2021	
Room 225	4.31	75%	33	9/8/2021	
Room 226					Under review
Room 314	13.16	50%	59	9/8/2021	
Room 306	12.78	50%	23	9/8/2021	
Room 310	15.76	50%	25	9/8/2021	
Room 311	16.46	50%	26	9/8/2021	
Room 312	16.88	50%	27	9/8/2021	
Room 313	9.42	50%	21	9/8/2021	
Room 318	2.22	50%		9/8/2021	Under review
Room 319	8.28	50%	17	9/8/2021	
Music 3rd	9.15	50%	153	9/8/2021	
Art 3rd	6.44	50%	115	9/8/2021	
Language 3rd	7.62	50%	138	9/8/2021	
Commons 1 (1st)	7.62	50%	104	9/8/2021	
Commons 2 (1st)	2.99	50%	25	9/8/2021	
<b>Science and Engineering</b>					
Room 102		50%		10/14/2021	Under review
Room 104	11.49	50%	50	10/14/2021	
Room 106	7.29	50%	44	10/14/2021	
Room 107		50%		10/14/2021	Under review
Room 108		50%		10/14/2021	Under review
Room 109		50%		10/14/2021	Under review
Room 110	7.25	50%	64	10/14/2021	
Room 111	6.21	50%	39	10/14/2021	
Room 201		50%		10/14/2021	Under review
Room 210	4.86	75%	40	10/14/2021	
Room 212		50%		10/14/2021	Under review
Room 214	4.62	50%	56	10/14/2021	
Room 304	49.27	50%	374	10/14/2021	
Room 305		50%		10/14/2021	Under review
Room 306	5.58	50%	24	10/14/2021	
Room 307B		50%		10/14/2021	Under review
Room 308	48.80	50%	359	10/14/2021	

Room 309		50%		10/14/2021	Under review
Room 311	12.19	50%	86	10/14/2021	
Room 312	11.96	75%	23	10/14/2021	
Room 318		50%		10/14/2021	Under review
Room 322	11.66	50%	70	10/14/2021	
Room 322A	8.42	50%	24	10/14/2021	
Room 326	6.92	75%	25	10/14/2021	
<b>SMAST East</b>					
Room 101	9.66	50%	33	10/14/2021	
Room 102	5.87	75%	39	10/14/2021	
Room 103	6.13	75%	21	10/14/2021	
Room 247	5.60	75%	20	10/14/2021	
<b>SMAST West</b>					
Room 204	9.18	25%	16	10/14/2021	
<b>Textile Bldg</b>					
Room 102	6.16	25%	12	10/14/2021	
<b>Violette Research Bldg</b>					
Room 209	9.35	25%	20	10/14/2021	
<b>Modular Trailer #2</b>					
Room 3	7.50	25%	2	9/8/2021	
Room 4	7.63	25%	2	9/8/2021	
Room 5	10.06	25%	2	9/8/2021	
Room 6	7.81	25%	2	9/8/2021	
Room 7	7.50	25%	2	9/8/2021	
Room 9	10.85	25%	2	9/8/2021	
Main Space	11.73	25%	10	9/8/2021	
<b>Modular Trailer #3</b>					
Office 1	7.09	25%	2	9/8/2021	
Office 2	7.56	25%	2	9/8/2021	
Room 2	6.21	25%	1	9/8/2021	
Room 3	7.17	25%	2	9/8/2021	
Room 7	7.56	25%	2	9/8/2021	
Main Space	8.93	25%	7	9/8/2021	
<b>Modular Trailer #4</b>					
Room 1	9.74	25%	2	10/14/2021	
Room 2	9.70	25%	2	10/14/2021	
Room 3	11.40	25%	3	10/14/2021	
Room 4	6.66	25%	3	10/14/2021	
Main Space	9.34	25%	9	10/14/2021	